




CCC Facility Services

CCC Facility Services Pty Ltd

SAMPLE ONLY



KESS 4.0 Report

Energy efficient compressed air solutions
Conducted by Mobile Compressed Air



KESS 4.0 Report

Contents





Requirements analysis


Scope conditions

Analysis Period	30/06/2025, Mo 11:17	⇒	07/07/2025, Mo 11:17
Working weeks per year	52 weeks		
Projected annual consumption of compressed air	195,682 m ³		
SAMPLE ONLY			
Electricity price	0.20 AUD/kWh		
CO ₂ emission factor	470 g/kWh		
Maximum allowed pressure	7.50 bar(g)		
Minimum required pressure	6.00 bar(g)		



Compressed air consumption

Volume flow during analysis period - 30/06/2025 - 07/07/2025





Solution comparison


Table

Scenario			FAD	V _{Eff}	Differential pressure across air treatment	Control	E _Σ	Energy costs	CO ₂	P _{Spec}
			m ³ /min	m ³	bar		kWh	AUD	t	kW/(m ³ /min)
Existing Station	<input type="checkbox"/>	<input type="checkbox"/>	10.29	1.1	0.0	SAMPLE ONLY	97,055	19,411	45.6	29.76
Scenario 1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	3.50	3.1	0.0	Local	27,192	5,438	12.8	8.33
Scenario 2	<input type="checkbox"/>	<input type="checkbox"/>	5.04	3.1	0.0	Local	32,206	6,441	15.1	9.87
Scenario8	<input checked="" type="checkbox"/>	<input type="checkbox"/>	6.00	3.1	0.0	Local	28,817	5,763	13.5	8.83



Solution comparison


Energy costs





Solution comparison


Energy overview





Solution comparison

Energy distribution






System description

Existing Station

Process flow diagram





System description

Existing Station

Max. delivery volume flow at max. pressure

10.29 m³/min

Import from ADA 4.0

Effective buffer volume

1.15 m³

Differential pressure via treatment


0.0 bar

Control method

With variable speed compressors

 **SAMPLE ONLY** 

With water cooled compressors



El. energy consumption per year	97,055 kWh
El. energy costs per year	19,411 AUD
CO₂ equivalent per year	45.6 t
Specific power	29.76 kW/(m³/min)
Energy savings per year	0 kWh
Energy costs savings per year	0 AUD



System description

Existing Station

Utilized compressors - Datasheet values

	Manufacturer	Sales type	YOP	p_{Max}	$P @ p_{Max}$	$FAD @ p_{Max}$	$P_{Spec} @ p_{Max}$	P_{Idle}
				bar(g)	kW	m^3/min	$kW/(m^3/min)$	kW
C1	Compressor 1	GA 55 - 7,5	2003	7.50	67.70	10.29	6.579	15.10

SAMPLE ONLY



System description

Existing Station

Utilized compressors - Simulation values

	Manufacturer	Sales type	YOP	t _{Load}	t _{Idle}	Load energy	Idle energy	Total energy	Delivered volume	P _{Spec}
				h	h	kWh	kWh	kWh	m ³	kW/(m ³ /min)
C1	Compressor 1	GA 55 - 7,5	2003	316	4.628	20,561	76,494	97,055	195,683	29.76


SAMPLE ONLY



System description

Scenario 1

Process flow diagram





System description

Scenario 1

Max. delivery volume flow at max. pressure

3.50 m³/min

ASK34SFC + 2m3 Tank

Effective buffer volume

3.15 m³

Differential pressure via treatment

0.0 bar


Control method

Local

With variable speed compressors

 **SAMPLE ONLY** 

With water cooled compressors



El. energy consumption per year	27,192 kWh
El. energy costs per year	5,438 AUD
CO ₂ equivalent per year	12.8 t
Specific power	8.33 kW/(m³/min)
Energy savings per year	69,863 kWh
Energy costs savings per year	13,973 AUD



System description

Scenario 1

Utilized compressors - Datasheet values

	Manufacturer	Sales type	YOP	p_{Max}	$P @ p_{Max}$	$FAD @ p_{Max}$	$P_{Spec} @ p_{Max}$	P_{Idle}
				bar(g)	kW	m^3/min	$kW/(m^3/min)$	kW
C1	KAESER	ASK 34 SFC	2025	8.00	24.40	3.50	6.971	2.60

SAMPLE ONLY



System description

Scenario 1

Utilized compressors - Simulation values

	Manufacturer	Sales type	YOP	t_{Load}	t_{Idle}	Load energy	Idle energy	Total energy	Delivered volume	P_{Spec}
				h	h	kWh	kWh	kWh	m ³	kW/(m ³ /min)
C1	KAESER	ASK 34 SFC	2025	1,365	1,494	21,722	5,470	27,192	195,756	8.33


SAMPLE ONLY



System description

Scenario 2

Process flow diagram





System description

Scenario 2

Max. delivery volume flow at max. pressure

5.04 m³/min

Effective buffer volume

3.15 m³

Differential pressure via treatment

0.0 bar

Control method


Local

With variable speed compressors

 **SAMPLE ONLY** 

With water cooled compressors

2xSK25 with additional 2m3 Tank



El. energy consumption per year	32,206 kWh
El. energy costs per year	6,441 AUD
CO₂ equivalent per year	15.1 t
Specific power	9.87 kW/(m³/min)
Energy savings per year	64,849 kWh
Energy costs savings per year	12,970 AUD



System description

Scenario 2

Utilized compressors - Datasheet values

	Manufacturer	Sales type	YOP	p_{Max}	$P @ p_{Max}$	$FAD @ p_{Max}$	$P_{Spec} @ p_{Max}$	P_{Idle}
				bar(g)	kW	m^3/min	$kW/(m^3/min)$	kW
C1	KAESER	SK 25	2023	8.00	17.20	2.52	6.825	4.60
C2	KAESER	SK 25	2023	8.00	17.20	2.52	6.825	4.60

SAMPLE ONLY



System description

Scenario 2

Utilized compressors - Simulation values


	Manufacturer	Sales type	YOP	t _{Load}	t _{Idle}	Load energy	Idle energy	Total energy	Delivered volume	P _{Spec}
				h	h	kWh	kWh	kWh	m ³	kW/(m ³ /min)
C1	KAESER	SK 25	2023	1,262	2,190	20,616	10,980	31,596	191,394	9.90
C2	KAESER	SK 25	2023	28	28	457	153	610	4,322	8.47



System description

Scenario8

Process flow diagram





System description

Scenario8

Max. delivery volume flow at max. pressure

6.00 m³/min

ASK34SFC+ SK25 + 2m3 Tank

Effective buffer volume

3.15 m³

Differential pressure via treatment

0.0 bar


Control method

Local

With variable speed compressors

 **SAMPLE ONLY** 

With water cooled compressors



El. energy consumption per year	28,817 kWh
El. energy costs per year	5,763 AUD
CO₂ equivalent per year	13.5 t
Specific power	8.83 kW/(m³/min)
Energy savings per year	68,238 kWh
Energy costs savings per year	13,648 AUD



System description

Scenario8

Utilized compressors - Datasheet values

	Manufacturer	Sales type	YOP	p_{Max}	$P @ p_{Max}$	$FAD @ p_{Max}$	$P_{Spec} @ p_{Max}$	P_{Idle}
				bar(g)	kW	m^3/min	$kW/(m^3/min)$	kW
C1	KAESER	ASK 34 SFC	2025	8.00	24.40	3.50	6.971	2.60
C2	KAESER	SK 25	2010	8.00	17.20	2.50	6.880	4.60



System description

Scenario8

Utilized compressors - Simulation values

	Manufacturer	Sales type	YOP	t _{Load}	t _{Idle}	Load energy	Idle energy	Total energy	Delivered volume	P _{Spec}
				h	h	kWh	kWh	kWh	m ³	kW/(m ³ /min)
C1	KAESER	ASK 34 SFC	2025	1,387	2,078	21,718	7,063	28,781	195,429	8.84
C2	KAESER	SK 25	2010	1,387 ₂	2,078 ₀	21,718 ₃₃	7,063 ₃	28,781 ₃₆	195,429 ₃₁₂	6.85



Legend


Part 1

p_{Max}	Maximum pressure on which a compressor can be operated
$P @ p_{Max}$	Electrical power consumption of a complete compressor during load at p_{Max}
$FAD @ p_{Max}$	Delivery volume flow of a compressor at p_{Max}
$P_{Spec} @ p_{Max}$	Specific power consumption of a compressor at p_{Max}
P_{Idle}	Electrical power consumption of a complete compressor during idling.
t_{Load}	Load time of a compressor SAMPLE ONLY
t_{Idle}	Idle time of a compressor
	The scenario has at least one compressor with variable speed
	The scenario has at least one compressor with water cooling
FAD_{Σ}	Total delivery volume flow of a considered compressed air station
V_{Eff}	Effective buffer volume of a considered compressed air station
E_{Σ}	Total electrical energy consumption of all compressors in a station calculated up on one year
P_{Spec}	Specific power of compressed air generation



Legend

Part 2





Contact Us

COMPRESSEDAIR.COM.AU

info@compressedair.com.au

08 8281 1677

SAMPLE ONLY

75 Rundle Road, Salisbury, South Australia 5106